Mr. Mark A. Gouveia, Production Manager **Southern Energy Delta, L.L.C., Contra Costa** P.O. Box 249 Antioch, CA 94509

Dear Mr. Gouveia:

Re: Southern Energy Delta, L.L.C., Contra Costa- Facility #A0018

Final Minor Revision/Administrative Permit Amendment

Roberta Cooper Scott Haggerty Mary King Shelia Young

CONTRA COSTA COUNTY

Mark DeSaulnier

Mark Ross

Gayle Uilkema

MARIN COUNTY
Harold C. Brown, Jr.
NAPA COUNTY

Brad Wagenknecht

SAN FRANCISCO COUNTY

Amos Brown

Michael Yaki

SAN MATEO COUNTY Michael D. Nevin (Chairperson)

Marland Townsend

SANTA CLARA COUNTY
Randy Attaway
(Vice Chairperson)
Don Gage
Julia Miller
Dena Mossar

SOLANO COUNTY
William Carroll
(Secretary)

SONOMA COUNTY
Tim Smith
Pamela Torliatt

Ellen Garvey
Executive Officer/
Air Pollution Control Officer

This is to advise you that the Bay Area Air Quality Management District is issuing administrative permit amendments and minor revisions to the Major Facility Review Permit for Southern Energy Delta, Contra Costa Power Plant (Facility Number A0018).

The District has made administrative amendments to standardize the wording of Section I, Standard Conditions; Section III, Generally Applicable Requirements; Section IV, Source-Specific Applicable Requirements; make changes to the dates of District and SIP rules; and delete out-dated SIP rules. An additional change has been made to the dates of the monitoring reports and compliance certifications.

Your facility retired sources S-31 and S-32 Cold Cleaners in the summer of 1999. Therefore, an administrative amendment was made to remove these sources from the Permitted Source List (Table II-A), Section IV, Source-Specific Applicable Requirements; and Section VII, Applicable Emission Limits & Compliance Monitoring Requirements.

Your facility has been issued an Authority to Construct to retrofit boiler S-10 with selective catalytic reduction (SCR) to comply with the requirements of District Regulation 9, Rule 11 (Nitrogen Oxides and Carbon Monoxide from Electric Power Generating Boilers). The installation of the SCR will not increase the rated capacity of the boiler and is expected to comply with District Regulation 9-11-310 for CO emissions. Emissions of other criteria pollutants as well as the toxic emissions, with exception of ammonia, are expected to remain unchanged or be decreased. A minor revision was made to include abatement device A-10 in Table II-B.

A copy of the final modified Major Facility Review Permit is enclosed for your information. If you have any questions on this matter, please call **Weyman Lee, Air Quality Engineer II, at (415) 749-4708.**

Very truly yours,

Ellen Garvey, Executive Officer/ Air Pollution Control Officer

EG:WNL:myl Enclosures

cc: Ronald M. Kino, Southern Energy Delta, L.L.C., Contra Costa Joseph H. Bittner, Southern Energy Delta, L.L.C., Contra Costa

h:\pub_data\titlev\permit\issue-p\00October\A0018.doc